



## FIRE ALARM REQUIREMENTS EDUCATIONAL

CITY OF LACONIA FIRE PREVENTION DIVISION  
848 NORTH MAIN STREET, LACONIA, NH 03246

Call (603) 524-6881 for appointments and information

FIRE  
PREVENTION  
Fire Alarms

200-17

March 2025

### New and Existing Educational Occupancies:

**New and Existing:** Required for all newly constructed educational occupancies

The fire alarm requirement shall not apply to educational occupancies meeting the following criteria:

- (1) The building does not have a gross area over 1,000 square feet
- (2) The building contains only one classroom
- (3) The building is located not less than 30 feet from another building

In **NEW** educational occupancies carbon Monoxide detection is required.

### Initiation of the fire alarm shall be by:

Manual means.

Approved automatic sprinkler system that provides protection throughout the building.

### Emergency Forces Notification:

**New:** Upon activation of the building fire alarm system.

**Existing:** By school authorities once a fire has been determined to exist.  
Upon activation of the building fire alarm system.

In cases where instruction is incidental to some other occupancy, the section of these regulations governing the other occupancy shall apply.

Sunday Schools or church schools that are not used for daily classes throughout the week shall comply with that section of this chapter dealing with **Places of Public Assembly and Day Care Centers.**