



MEANS OF EGRESS AND EMERGENCY SYSTEMS FOR TEMPORARY STRUCTURES USED AS PLACES OF ASSEMBLY

CITY OF LACONIA FIRE PREVENTION DIVISION
848 NORTH MAIN STREET, LACONIA, NH 03246

Call (603) 524-6881 for appointments and information

FIRE PREVENTION Safety 400-6

March 2025

Means of Egress:

All means of egress; doors, pathways, dedicated openings, and stairs; shall be kept clear of obstructions or impediments that may interfere with the operation of the exit or limit the ability of people to exit the occupancy. The exit shall be kept clear from the **EXIT** to a public way (**EXIT DISCHARGE**).

Emergency Systems and Devices: (As determined by the Authority Having Jurisdiction)

Emergency Lights:

Emergency lighting powered by electrical services and with battery back-up shall be provided adjacent to each exit and at any intermediate point required by the Authority Having Jurisdiction (AHJ) to provide sufficient emergency lighting during an emergency.

Exit Signs:

Self-contained, internally illuminated EXIT sign shall be placed over each exit and shall be visible.

These systems shall be installed in accordance *with the current edition of NFPA 101, Life Safety Code and NFPA 70, National Electrical Code.*

Temporary Permits of Assembly:

Permits of Assembly must be obtained from the Laconia Fire Department prior to occupying any place of assembly.

Total occupancy will be based on actual conditions found during the place of assembly inspection and in accordance with the current edition of **NFPA 101, Life Safety Code.**