



## EMERGENCY – FIRE ACCESS TO STRUCTURES

CITY OF LACONIA FIRE PREVENTION DIVISION  
848 NORTH MAIN STREET, LACONIA, NH 03246

Call (603) 524-6881 for appointments and information

**FIRE  
PREVENTION  
Safety  
400-8**  
March 2025

In order to maintain adequate emergency accessibility to structures and other property, the following minimum access / fire lane widths apply:

### **GENERAL:**

Fire lanes and access roads shall be a minimum of 20 (twenty) feet clear width accessible during all times of the year and without reduction for snow accumulation. If parking along a designated fire lane is provided, the clear width of the road shall be expanded to incorporate the parking width required and maintaining the required clear width for the designated fire lane.

Use of security access gates and the methods of operation shall be approved by the fire chief prior to installation. Adequate devices or methods for all Laconia Fire Department apparatus are required.

Buildings shall meet all requirements of NFPA 1: 18.2 Fire Department Access.

### **PLACE OF ASSEMBLY:**

Wherever possible, two separate emergency access roads or fire lanes shall be maintained for all places of assembly. If only one access road is provided for this assembly, a minimum of 24 (twenty-four) feet clear width without reduction for snow accumulation shall be provided.

### **EDUCATIONAL FACILITY:**

Wherever possible, two separate emergency access roads or fire lanes shall be maintained for all places of assembly. If only one access road is provided for this assembly, a minimum of 24 (twenty-four) feet clear width without reduction for snow accumulation shall be provided.

Additional reductions may apply if the building(s) are provided with a fire suppression (sprinkler) system or fire-rated wall and penetration assemblies approved by the Authority Having Jurisdiction.

