

Laconia Fire Department

848 North Main Street
Laconia, New Hampshire 03246

IN SERVICE INSPECTION - BUSINESS OCCUPANCY

Property Name: _____ Tel: _____

Street No: _____ Street: _____

Owner: _____ Owner Tel: _____

Contact: _____

1. Yes No Emergency Lights Operational?
2. Yes No Positioned properly, sufficient light in egress path?
3. Yes No Exit signs present, visible, and illuminated internally or by Emergency Lights?
4. Yes No Fire Extinguishers present?
5. Yes No Fire Extinguishers mounted?
6. Yes No Fire Extinguishers of the proper type and size for the hazard?
7. Yes No Fire Alarm System present? Connected To: _____
8. Yes No Vertical Openings protected by "solid core wood" or steel doors?
9. Yes No Apartments above or beside separated by ONE hour rated construction?
10. Yes No Storage areas separated from other areas?
11. Yes No All areas free of excess combustibles. Stock properly stored?
12. Yes No Trash containers available and emptied on regular basis?
13. Yes No Means of Egress readily visible, clear, and unobstructed?
14. Yes No Two remote exits available? Doors open toward outside?
15. Yes No Exit doors open without excessive force. [CRASH BARS for over 100]
16. Yes No Path to street open and unobstructed from Exit door?
17. Yes No Proper use of electrical cords? All fixtures and lighting on permanent wiring?
18. Yes No Employees trained in Fire Exit procedures?
19. Yes No Employees trained in proper use of Fire Extinguishers?

GENERAL COMMENTS: _____

Inspected by: _____ Date: _____